This Datasheet for the

# IC660BBR101

Block Relay Output Normally Open 16 Circuits

June 2002

#### Description \_

Relay Output blocks provide 16 output circuits in four independent groups of four relay-type outputs each. The block power may be either 115V or 230V AC. There are two types of Relay Output blocks:

- Normally-Closed Relay Output Block (IC66\*BBR100), Normally-closed contacts
- Normally-Open Relay Output Block (IC66\*BBR101), Normally-open contacts

Relay blocks are compatible with a wide range of low-power control and indicating devices such as relays, contactors, and lamps. Output devices may operate in the range of 5V to 250V AC or 5V to 220V DC, and switch up to 60 Watts or 125 VA.



#### Features

Each group of four outputs on a Relay Block can be powered by a separate AC or DC source. Group to group isolation is 1500 volts. Block features include:

- Output powerup defaults
- Output Hold Last State or default
- CPU Redundancy type
- Bus Switching Module control

#### Using this Datasheet

This datasheet summarizes information about block installation, configuration, and diagnostics.

Your primary reference should be the *Discrete and Analog Blocks User's Manual*. It includes detailed instructions for block installation and configuration.

For additional information about systems and communications, including bus specifications, refer to the *I/O System and Communications Manual*.

#### Specifications \_\_\_\_\_

Catalog Number							
Output Block, No	ormally-	IC66*BBR100					
Closed Relays	Assembly IC66*EBR100						
	Electronics Assembly Terminal Assembly						
Output Block, No			6*BBR				
Open Relays	Jinany	100	C66*BBR101				
Electronics Assembly			6*EBR	101			
Terminal As	IC	6*TBR	101				
Block Specifica	tions						
Size (height x wi							
depth)		3.91" (9.93cm)					
Weight			4 lbs. (1.8 kg)				
LEDs (I/O Block)			Unit OK, I/O Enabled				
LEDs (each circ			lividual r	relay coil	state		
Environmental S							
Operating tempe					2° to +140° F)		
Storage tempera	ature				0° to +212° F	)	
Humidity					ndensing)		
Vibration				2" (5.08n	nm) displacer	nent, 10-200 Hz at	
		1G					
Block Power Sp	ecifications						
Frequency			-63 Hz	02 to 12			
Operating voltage Power requirement			mA at 1		2040, (23007	AC) 185 to 265VAC	
Power supply dr		-	ycle	IJ VAC			
,	opout time	10	yeie				
Isolation		-1		4500 1/	10		
All outputs to cha		a		1500 V			
Between output Power terminals		arou	nd	1500 V			
Power terminals		grou	nu				
Comms terminal		term	1500 VAC inals 1700 VDC				
Comms terminal			inais	1500 VAC			
Heat Dissipation		-				16 outputs on	
Output Specific							
Maximum Outpu				2 Amps per circuit			
Maximum switch				60 Watts or 125 VA			
Maximum inrush current				2 Amps per circuit			
Output OFF leakage current			0.1 mA				
Maximum switching frequency				20 cycles/minute (inductive loads)			
Output turn-on delay (maximum)			)	5ms			
Output voltage range			5V to 250V AC or 5V			' to 220V DC	
Minimum recom		d		10mA			
Relay Specificat	tions						
Relay Type	! . !		Fixed coil moving arm 100 milliohms, maxim				
Initial Contact Re Typical Life:	esistance			100 mii	lionms, maxir	num	
Operating	Max	imur	n Currei	nt for Loa	d* Type	Typical Life	
Voltage	Resistiv		1	mp	Solenoid	(operations)	
250VAC	0.5A	•				200,000	
250VAC			0.1A		0.1A	100,000	
125VAC	1.0A		0.2A		0.3A	100,000	
220 VDC	0.3A					100,000	
110 VDC	0.6A					100,000	
30VDC	2.0A					500,000	
30VDC			0.2A		0.3A	100,000	
12VDC			0.3A		0.5A	100,000	
Effect of Load of	on Operatin	ng Li	ife				
Operating		Си	irrent in	Load Ty		Typical Life	
Voltage	Resistiv	e		тр	Solenoid	(operations)	
250VAC	0.1A -					1,500,000	
	0.3A					1,000,000	
125VAC	1 0 4					2,000,000	
125VAC 30VDC	1.0A						
125VAC 30VDC 12VDC	2.0A					1,000,000	
125VAC 30VDC 12VDC * Lamp loads ar	2.0A e defined a					(PF) of 1.00; when	
125VAC 30VDC 12VDC * Lamp loads ar	2.0A e defined a represent	a PF	of 1.00	. Solenc	ids are define	(PF) of 1.00; when ed as a X10 inrush	

GFK-0038E

June 2002

#### Compatibility

These blocks are compatible with a Hand-held Monitor identified by catalog number IC66\*HHM501 only.

For an IC697 series PLC, the CPU and programming software must be version 2.0 or later. The Bus Controller must be IC697BEM731C or later.

For an IC600 series PLC, the CPU must be rev. 105 or later. For an IC600 "Plus" series PLC, rev. 110 or later is required. The programming software must be rel. 4.02 or later.

For an IC550 series PLC, the CPU must be rev. 3.0 or later. The programming software must be rel. 2.01 or later.

#### Installation Instructions

Carefully inspect all shipping containers for damage. If any equipment is damaged, notify the delivery service immediately. Save the damaged shipping container for inspection by the delivery service. After unpacking the equipment, record all serial numbers. Save the shipping containers and packing material in case it is necessary to transport or ship any part of the system.

#### **Block Mounting**

Genius I/O blocks are considered "open equipment" and therefore must be installed within a protective enclosure. They should be located in an area that is clean and free of airborne contaminants. There should be adequate cooling airflow.

The block can be mounted right side up, or upside down. Leave at least 2 inches of space between blocks. Mount the block by drilling two screw or bolt holes for 8-32 hardware. Position the block so that the notches in the upper and lower flanges line up with the mounting holes. Mount the block using 8-32 screws. Use star washers to provide ground integrity.

#### Grounding

The block's mounting screws must not be used as the only means of grounding the block. Connect the green ground screw on the block to a reliable ground system using a short wire lead, minimum size AWG #12 (avg 3.3mm<sup>2</sup> in cross-section).

#### Warning

If mounting screws do not make good ground connection and the ground screw is not connected to a reliable ground, the block is not grounded. Electrical shock hazard exists. Death or personal injury may result.

#### Block Wiring

Do not overtorque the terminal screws. Recommended torque for all terminals is 6 in/lb (.678 N/M).

#### Serial Bus Wiring

Using one of the cable types recommended in the *System and Communications User's Manual* connect the serial bus to terminals 1-4 as shown. (If the block will be used as a BSM controller, do not attach the serial bus to terminals 1-4. See "Using a Relay Block as a BSM Controller" instead).

Terminals 1 to 4 are for the serial bus. These terminals accept one AWG #12 wire (avg 3.3mm2 cross-section) or two AWG #14 wires (each avg 2.1mm2 in cross-section). The minimum recommended wire size is AWG #22 (avg .36mm2 in cross-section). Terminals 1 - 4 can also accommodate spade or ring terminals up to 0.27 inch (6.85mm) wide with a minimum opening for a #6 screw, and up to 0.20 inch (5.1mm) depth from the screw center to the back barrier. Be sure unshielded wire ends are not longer than 2 inches (5 cm).

If the block is at either end of the bus, connect a terminating resistor of the appropriate type (see the *System and Communications User's Manual* for details) across its Serial 1 and Serial 2 terminals.



#### Using a Relay Block as a BSM Controller

A Relay block can be used to control a Bus Switching Module. There are two different BSM versions available. It is important to match the BSM to the type of voltage that will power the block's outputs. If the voltage will be 24/48 VDC, BSM version IC66\*BSM021 is required. If the voltage will be 115 VAC or 125 VDC, IC66\*BSM120 is needed instead.

Install the BSM at the block's serial bus terminals, as described in the *Bus Switching Module datasheet*. Connect the bus cable to the BSM. Connect the BSM wires to the block as explained below.

#### Field Wiring

Terminals 5 to 32 are for field devices. They take a single wire up to AWG #14 (avg 2.1mm2 in cross-section). Minimum recommended size is AWG #20 (avg .54mm2 in cross-section).

Power for AC loads may come from the block AC power supply or other AC source(s). Power for DC loads may come from one or more DC sources. Each group may use a separate AC or DC source.



June 2002

Relay Output blocks require a 115 VAC or 230 VAC power source. Voltage selection is made by jumpers on the Terminal Assembly. When shipped from the factory, the power selection jumpers are set for 115 VAC operation. For 230 volt AC power, change the jumpers as shown. Correct jumper placement is important; incorrect jumper placement may result in damage to the block. Connect the power source to the H and N terminals (5 and 8).

For applications where Class 1 Division 2 conditions must be met for Factory Mutual, install an external 250 volt 1/8 amp slow-blow fuse in series with the Hot AC power connector as shown below.



With the external fuse indicated, this block meets FM Class 1 Divi

#### sion 2 requirements. Block and Points Powered by 115VAC

If the block and points are powered by 115 VAC, connect one wire of BSM version IC66\*BSM120 to point 1 and connect the other BSM wire to N. Jumpering terminal J1 to COM as shown above right allows the points to operate on the same 115 VAC source that powers the block.



#### Block Powered by 230VAC, Points Powered by 24-48VDC

If the block is powered by 230VAC and the points are powered by a 24-48 VDC source, connect one wire of BSM version IC66\*BSM021 to point 1 and the other to DC- (24-48VDC).



## Block Powered by 23VAC, Points Powered by 115VAC or 125VDC

If the block is powered by 230 VAC and the points are powered by either a 115 VAC source or a 125 VDC source, use BSM version BSM120. Connect one wire of the BSM to point 1. For a 125 VDC source, connect the other BSM wire to DC-. For a 115 VAC source, connect the other BSM wire to the neutral side of the power supply.



#### **External Fuses and Snubbers**

Relay blocks have no internal fuses. Following normal practices, external fuses of 2 Amps or less can be installed in series to protect loads.

External snubbers are not necessary for correct operation of the block. However, the use of snubbers is recommended. Snubbers will reduce switching transient pulses and lengthen the contact life of the relays. Use a diode connected in parallel with a DC inductive load or an R-C network across the contacts.

#### Removing an Electronics Assembly

The block's Electronics Assembly can be replaced with a compatible model without removing field wiring or reconfiguring the block.



- 1. Unscrew the retaining screws at the top and bottom of the block.
- Using a Block Puller (IC660BLM507), engage the tabs in the first vent slots. Move the tool to the center of the block and squeeze the handle.
- 3. Pull the Electronics Assembly upward.



If power is applied to the field terminals, power is also exposed on the connector pins at the base of the Terminal Assembly, and electrical shock hazard exists. Do not touch the connector pins! Death or injury may result.

June 2002

#### Inserting an Electronics Assembly

1. Align the Electronics Assembly in the guides and push down firmly.

Caution

#### Do not exert excessive force; it may damage the block.

- If unusual resistance is met, remove the Electronics Assembly. If power is applied to the block, DO NOT TOUCH THE CONNECTOR PINS! Inspect the Terminal Assembly, connector receptacle, and connector edge board (on the Electronics Assembly). Be sure the keying matches. Remove any obstacles and reinsert the Electronics Assembly. Pay close attention to the alignment of the guide pins.
- 3. Secure the Electronics Assembly with the screws on the top and bottom of the Terminal Assembly.

#### Block Operation \_\_\_\_

All 16 relay-type outputs are either normally-open or normallyclosed, depending on the block version. Outputs are grouped into four groups of four relays. Each group of four shares a common input terminal.

Each circuit has its own LED that shows the commanded state of the coil. A logical '1' received from the CPU causes the block to energize the corresponding relay coil, and '0' causes the coil to be deenergized. This has opposite effects on these two blocks. When the coil of a normally-open relay is energized, the relay is energized and the relay contact closes. When the coil of a normally-closed relay is energized, the relay contact opens.

The Relay Output blocks provide an EEPROM Failure diagnostic only. There are no diagnostics associated with the individual circuits.

Circuit LEDS show the commanded state of each coil.



Note: Relay Normally-Open version shown. Normally-closed is the same, except for relay type.

#### LEDs

The block's Unit OK and I/O Enabled LEDs show its operating status:

Unit OK	l/O Enabled	Meaning	
ON	ON	Block functioning, CPU communicating	
ON OFF		Block functioning	
		No CPU communications for 3 bus scans	
ON	Blinking	Block functioning, Circuit forced	
Blinking	ON	Circuit fault, CPU communicating	
Blinking OFF		Circuit fault	
		No CPU communications for 3 bus scans	
Alternate Blinking		Circuit fault, Circuit forced	
Synchronous Blinking		No CPU communications - block number conflict	
OFF	Don't Care	No block power, or block faulty	

Individual circuit LEDS show the commanded state of each coil.

#### Configuration

First, the block must be configured with a Hand-held Monitor to:

- Enter its Device Number (serial bus address).
- Enter its Reference Number (required only for IC600 and IC550 series PLCs only).

*Note:* If a block is configured offline, it must be properly grounded and have a 75 Ohm resistor installed across its Serial 1 and Serial 2 terminals. See the *Discrete and Analog I/O Blocks User's Manual* for instructions. The rest of the features can be configured either using a Hand-held Monitor, or by sending a Write Configuration datagram to the block from the host.

Feature	Circuit or Block	Factory Setting	Selections				
Device Number	Block	null	0 to 31 (a number must be selected)				
Reference Address	Block	none	Depends on host CPU type				
Baud Rate	Block	153.6 std	153.6 std, 153.6 ext, 76.8, 38.4 Kbd				
Hold Last State	Circuit	no	yes, no				
Output Def. State	Circuit	coil off	coil on, off				
BSM Present	Block	no	yes, no				
BSM Controller	Block	no	yes, no				
Outputs Default Time	Blockl	3 bus scans	2.5, 10 seconds				
Redundancy Mode	Block	none	none, duplex, hot standby				
Duplex Default	Block	off	on, off				
Configuration Protection	Block	disabled	enabled, disabled				